

SOQ FOR ELECTRICAL WORK GA WING SURPLUS AREA AT 3RD FLOOR, DWARAKANATH BHAWAN					
SL.NO	DESCRIPTION OF ITEMS	UNIT	QUANTITY	RATE	AMOUNT
	INTERNAL POINT WIRING				
1	POINT WIRING				
	Supply, Installation, Testing & Commissioning of light points, 5A socket outlets, exhaust fan points using necessary materials like 25mm dia PVC Conduit & other conduit accessories, using 2R x 1.5 +1R x 1.5 Sqmm FRLS category & insulated MSCC wires, 16G GI box and other point wiring accessories & carrying out surface / concealed wiring. The rate shall include earthing of all points. The quoted rates shall also include PVC coated metal flexibles & all accessories, tools, labour etc. No separate payment will be made for wall chasing, cleaning of debris, rough plastering the chased wall / floor. The rate shall include looping between points. The wiring size is limited to lighting circuits (Max.800W) & 5A power outlets in point wiring limited to 200W per socket outlet & looped to a max.of 4 outlets. All accessories shall be IS approved.				
	Chipping in wall for installation of conduits, putting JBs/DBs in wall, taking cable in wall, chipping to be carried out within precast bricks / blocks etc. after installation, doing proper plastering with cement and complete the job in accordance with direction of engineer in charge.				
	Special notes for quoting point wiring :				
	i) Make of switches as per approved list.				
	ii) The max. nos. of points that may be considered for one circuit shall be eight points or less such that connected load is equal to or less than 800 watts.				
	iii) The rate shall include looping between switch/socket/Exhaust fan/light points etc. 2 X 1.5 + 1 X 1.5 SQMM MSCC PVC Insulated wires.				
	iv) The rate shall be worked out considering the average ceiling height of 3.35 mtrs high. However, it is the responsibility of the contractor to ensure that all building parameters, including height, possible length of wiring required in accordance with point wiring is assessed & included in the rate. No extra claims will be entertained on this account.				
1.1	One light point controlled by a 6A switch (2x2 light fixtures & Linear Lights)	Nos.	10		
1.2	Two light point controlled by a 6A switch	Nos.	5		
1.3	Three light point controlled by a 6A switch	Nos.	5		
1.4	6A, 3/5 pin, receptacle controlled by 6A switch located near light switch control. (half point)	Nos.	5		
1.5	6A 3/5 pin receptacle controlled by 6A switch located independently (full point) (Up to 6mtr)	Nos.	5		
1.60	6A 2/3 pin receptacle located on wall or column controlled by 6A switch for exhaust fan & Wall fan (switch & receptacle located separately)		5		
2	LIGHTING, UPS AND RAW POWER WIRING :				
2.1	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V Grade, multistrand Copper with low conductor resistance single core wire in open or concealed system of wiring with as per IS-694: confirming to latest amendments. The rate shall include necessary crimping lugs , with all necessary accessories.				
	a) 4R x 6.0 sqmm + 1R x 6.0 sqmm (For Lighting, Raw power, UPS and AC DB)	MTR	50		
2.2	Supplying and Drawing flexible multicore FRLS cable manufactured with electrolytic grade flexible copper conductor confirming to table 3 class 5 of IS:8130-1984 and (virgin) PVC insulation and sheathed suitable for working voltage upto 1100volts as per IS-694:1990. The rate shall include necessary crimping lugs , with all necessary accessories.				
	a) 3Cx2.5Sqmm CU.Flexible (For Lighting Circuit mains, UPS Circuit mains, looping and IDU AC Units circuits and looping, Raw Power Circuits)	MTR	500		
	b) 3Cx4 Sqmm CU.Flexible	MTR	75		

2.3	UPS /COMPUTER POINTS				
2.3.1	Supply & fixing of 6/16A, 6 pin, commercial type switched socket outlet with indicator , G.I.box, cover plate and all wiring accessories including interconnection etc., complete. The box shall be flush/surface mounted on wall as required. (For Raw power & UPS)	Nos.	6		
2.3.2	Supply & fixing of 2 Nos. x 10A, 1 phase Universal type 5 Pin socket outlets Controlled by 1 No. 16A Switch for UPS points with G.I box, cover plate & all wiring accessories including interconnection etc. mounted on wall / Partition / Workstation Table as required. (For W/s UPS)	Nos.	10		
2.3.3	Supply & fixing of 2 Nos. x 10A, 1 phase Intel International type 3 Pin socket outlets Controlled by 1 No. 10A Switch for UPS points with G.I box, cover plate & all wiring accessories including interconnection etc. mounted on wall / Partition / Workstation Table as required.	Nos.	61		
3	INTERNAL LIGHT FIXTURES				
3.1	Supply and fixing of recess mounting non integral type LED W luminaire comprising of pressure decast/extruded aluminium housing, with spring loaded false ceilin clamps, Power LEDs with CCT 6500 degree K, CRI >70%, efficacy >100 lumen per watt, 120 degree beam spread, life>25000 burning hours and compliance to IS 10322/IEC 60598, LM 79 & LM 80. The lamp compartment is enclosed with anti glare opal diffuser which enhances the lighting level. LEDs are driven by HF electronic driver integrated in a separate control gear assembly, with PF >0.95, power loss should <5% of lamp wattage, short circuit & open circuit protection to be integrated in a separate control gear assembly with PF >0.95, power loss should <5% of lamp wattage, short circuit & open circuit protection to be integrated in the circuit, THD less than 20%, Life as per LM 79. The operating input voltage should be between 130 to 275 volts. BIS approved and Tested by NABL/CPRI accredited laboratory with 2 years warranty against any manufacturing defect working under standard electrical condition.	For All Items under item no 3- Internal Light Fixtures,Items will be supplied by wing/section. Only Installation will be done by contractors.			
	LED modular down light 2'x2' 36W	Nos.	20		
3.2	Supply & fixing of recess mounting non integrated type LED down light W luminaire comprising of pressure decast/extruded aluminium housing, with spring loaded false ceilin clamps, LED of power /COB with CCT 6500 degree K, CRI>70% efficacy >100 lumen per watt, 120 degree beam spread, life>25000 burning hours and compliance to IS 10322/IEC 60598, LM 79 & LM 80. The lamp compartment is enclosed with anti glare opal diffuser which enhances the lighting level. LEDs are driven by HF electronic driver integrated in a separate control gear assembly, with PF >0.95, power loss should <5% of lamp wattage, short circuit & open circuit protection to be integrated in the circuit, THD less than 20%, Life as per LM 79. The operating input voltage should be between 130 to 275 volts. BIS approved and Tested by NABL/CPRI accredited laboratory with 2 years warranty against any manufacturing defect working under standard electrical condition.				
	b) 12 W	Nos.	15		
3.3	Supply & fixing of feet PVC Batten with integrated LED tubeW with high quality diffuser with Life of 25000 burning hours & 70% lumen maintenance with CRI >80. Power input :220-240 V @ 50/60 Hz & PF >0.9 along with CE approved. 2 years warranty against any manufacturing defect working under standard electrical condition.				
	LED light fitting 1x4' - 20/22w	Nos.	4		
3.4	Supply and installation decorative fixtures as per the approved design and instruction of the Bank' Engineers(Aproximate basic cost will be 2 lakhs)	Nos	0		
3.5	Recess Type Ceiling mounted Squarelight with size of 75mm x 75 mm) with 12 W.	Nos	10		

3.7	Supply & fixing - flexible LED Strip Light 30W Power consumption in 5 mtrs length CCT 6500 degrees K, CRI>70% efficacy > 80 Lumend per watt, life >25000 burning hours and Compliance to IS 10322/IEC 60598, LM 79 & LM 80. The LED are driven by HF electronic driver non integrated, with PF >0.95, power loss should <5% of lamp wattage, short circuit & open circuit protection to be integrated in the circuit, THD less than 20%, life as per LM 79. The operating input voltage should be between 130 to 275 volts. BIS Approved with 2 years warranty against any manufacturing defect working under standard electrical condition.	MTR	20		
3.8	Supply and fixing wall mounting fan suitable to operate at single phase 230v AC supply.(Design will be selected by the Engineer in charges basic price Rs 2500/-)	Nos.	13		
3.9	Supply & fixing of 1440RPM heavy duty exhaust fan with bracket blades suitable suitable to operate on 230V 50Hz, AC supply complete	Nos.	1		
3.10	Supply and fixing on wall call bell buzzer (approved by Consultant) suitable for 230 volt single phase A.C.supply including interconnection, etc. as required .	Nos.	3		
4.1	Supply and laying of Medium gauge PVC conduit pipedia....mm thick confirming to IS 2509 with suitable size bends, junction boxes, adhesives paste etc., and fixing using inverted wood plugs in case of RCC ceiling and RCC wal / stone structure or rawl plugs in case of brick walls and cement plastering the damaged portion using heavy gauge saddles at an interval of 700mm using NF screws.				
a	20 mm dia rigid 2mm thick PVC pipes of ISI mark	MTR	150		
b	25 mm dia rigid 2mm thick PVC pipes of ISI mark	MTR	150		
c	32 mm dia rigid 2mm thick PVC pipes of ISI mark	MTR	200		
4.2	Extra for Groove cutting in cc floor to the suitable depth for concealing of Conduit/Raceway's and plastering, finishing to the surface floor and complete accessories.				
	a) 50mm (w) x 50mm (d)	MTR	70		
4.3	RACEWAYS WITH COVER IN CEILING AND FLOOR FOR POWER & DATA CABLING				
4.3.1	Supply and laying Raceways of following sizes made of 1.6mm thick pregalvanised sheet steel complete with 2mm thick screwed counter sunk type screws / Push to fit type cover. The raceways shall be of ready made or fabricated GI type.				
	200mm x 38mm raceways without central barrier.	MTR	25		
	100mm x 38mm raceways without central barrier.	MTR	30		
4.3.2	Supply & Installation of Floor & Ceiling Boxes of following sizes made of 1.6mm thick pregalvanised sheet steel complete with 2mm thick screwed counter sunk type screws / Push to fit type cover.				
	210mm x 210 x 40 mm box	Nos.	5		
	110mm x 110 x 40 mm box	Nos.	5		
4.4	TRUNKING SYSTEM WITH OUT BARRIER (FOR DB AREA)				
4.4.1	Fabricating, supplying to site & installation on ceiling / surface 2.0 mm thick M.S. powder coated (Shade: Siemens Grey) cable trunking without central barrier of height 80 mm and 2.0 mm thick with and openable cover in tray form with gaskets on fixed part, totally enclosed to make it dust and vermin proof complete. Fully plated bolt, nut, 2 plain washer & a spring washer would be used.				
	a) 200x100mm	MTR	10		
4.5	Supplying and fixing 2mm thick Pre galvanised perforated cable tray on existing MS angle, Channel support using necessary GI bolts/nuts and washer or welding as required.				
	a) 150x50mm Wide perforated cable tray with 1no. 25x3mm flat at every 300mm using 12 mm threaded Rods. (Black colour powder coated)	MTR	50		
4.7	READY MADE DISTRIBUTION BOARDS				
	Supply, Installation, Testing, Erection and commissioning of Double Door Distribution boards, floor/wall mounted including transportation to site of erection, unpacking, assembling including transportation from owner's store / yard to site of erection, unpacking, assembly, installation on foundations or fixing to wall or steel structures, aligning, leveling, grouting, testing and calibration of relays and meters etc. including all labour and materials complete as per specifications of this tender. Bus bars of 125A rating with electrolytic grade copper for phase, neutral & earth as required.				

4.7.2	Supply, fixing and termination of 16 Way SPN MCB DB with incomer 40A,2P,MCB as incomer and 14 Nos ,SP,10KA, MCB 'C' Curve as outgoing (For UPS DB,Raw Power DB & Light DB)	Nos.	5		
4.7.3	Supply, fixing and termination of 12 Way SPN MCB DB with incomer 40A,2P,MCB as incomer and 10 Nos ,SP,10KA, MCB 'C' Curve as outgoing (For UPS DB & Light DB)	Nos.	3		
4.7.4	Supply & fixing of 20A, single phase, 3 pin, industrial type plug & socket with chained link and metal cover controlled by 20A, DP, MCB,10KA, 'D'Curve with indicator and G.I box, cover plate and all wiring accessories including interconnection etc., complete. The box shall be flush mounted in brick wall / partition / Floor.	Nos.	2		
4.8	Supplying and laying of 1.1KV Aluminium LT UG cable XLPE or heat resistant PVC insulated, PVC extruded inner sheathed, armoured UG LT cable as per the IS - 1554 (part-1) or IS-7098 part-1, Armoring strip thickness in average + 5% and resistivity 14 Ohms/Kms (Max) as per IS -3975. Cables laid in cable trays/clamped to wall/ceiling complete with necessary clamps and hard wares.				
	c) 3.5 core 185 sq.mm AL.AR.XLPE Cable (For Main panel)	MTR	30		
4.9	Supply & providing end terminations for the below listed XLPE aluminium cables with copper lugs, brass cable glands.				
	b) 3.5 core 25 sq.mm AL.AR.XLPE Cable (For 60KVA UPS Input enclosure)	Nos.	2		
	c) 3.5 core 185 sq.mm AL.AR.XLPE Cable (For Main panel)	Nos.	2		
4.10	CHEMICAL TREATED EARTH STATION AND EARTH STRIPS				
	Supply, installation, testing and commissioning of Dual GI MS Pipes sealed at both ends earthing electrode with flat full length copper terminal inside & filled with highly conductive, non corrosive, non magnetic moisture boosting chemical for Ground Resistance improvement as per detailed specification given below (must comply to IS 3043 -1987/NEC/IEE code of practice for earthing.) Chemical is also to be put around above pipe electrode in earth pit in form of slurry to retain moisture.				
	a) Type 1: This type will have pipe electrode which is 3m long & outer shell to have min 80 mm dia x 3.65 mm thick, inner shell to be max. 50mm dia x 3.25 mm thick. with Cu coating of 80 to 120 microns for outer shell & about 200 to 300 microns for inner shell. Terminal & electrode flat size should be 40 x 6 mm or equivalent copper conductor. Pipe Electrode will be laid inside a bore of about 200mm dia.	Nos.	1		
	b) Type 2: This type will have pipe electrode which is 3m long & outer shell to have min 80 mm dia x 3.65 mm thick, inner shell to be max. 50mm dia x 3.25 mm thick. with GI coating of 80 to 120 microns for outer shell & about 200 to 300 microns for inner shell. Terminal & electrode flat size should be 40 x 10 mm or equivalent GI conductor. Pipe Electrode will be laid inside a bore of about 200mm dia.	Nos.	1		
	c) GI strip 25x6mm	MTR	20		
	d) CU strip 25x3mm	MTR	10		
	e) Supplying and running GI/Copper conductor for grounding and (along with other wires in conduit system of wiring) using necessary suitable size clamps, nails, guttas/spacers etc., Copper wire 8SWG (For AC Body Earthing)	MTR	20		
5.1	Supply and fixing of double RJ11 telephone socket outlet with shutter module (2 module) with modular face plate and PVCbox of approved make in cabins /tables for intercom & telephone	No	160		
5.2	Supply and laying connecting & commissioning of 2 pair telephone cable for telephone intercompoints in 19mm dia PVC conduits laid in counters partitions/Wall with all accessories as required	RMT	3000		
5.3	Supply and Laying connecting & commissioning of 200 pair Krone Box with lock and Key fixed in the wall with all accessories as required	No	2		
5.4	Supply and laying 100 pair jelly filled unarmoured cable	Rmt	20		
5.5	Supply installation testing & commissioning of 1.5/3/6w ceiling speaker complete as required	No	5		
5.6	Supply laying connecting & commissioning of speaker cable two pair 2 core ,1.5 sqmm with fire retardant PVC insulated copper conductor cable in appropriate PVC conduit ISI marked along with the accessories in concealed system etc as required .The wiring should connected to UPS DB	Rmt	80		
In words,		SUB TOTAL		₹	
		CGST		₹	
		SGST		₹	
		GRAND TOTAL		₹	