

PROPOSED REFURBISHING WORK FOR MANBAZAR BRANCH

CANARA BANK CIRCLE OFFICE KOLKATA

II. SCHEDULE OF QUANTITIES FOR ELECTRICAL AND ALLIED WORKS

ITEM NO.	DESCRIPTION	QNTY.	UNIT	RATE		AMOUNT	
				RS.	P.	RS.	P.
1.0	SWITCH/ MCB						
1.1	Supply & erection of 415V/230V equipment individually on wall housed in MS enclosure with metal front cover for the following:						
1.1.1	100A FP SFU with HRC fuse links as main incomer with cable entry box.	1	Each				
1.1.2	63 A TPN Isolator with cutout DB for Master switch for controlling Lights, Acs., power point excluding UPS ,Server & CCTV wiring distribution at Branch Entrance location	1	Each				
1.1.3	40A DP RCCB (MAKE :LEGRAND/L&T)	1	Each				
1.1.4	32A 20KA 230-400V, 50/60HZ FP SURGE PROTECTION DEVICE(HAGER MAKE)	1	SET				
1.1.5	63 A DP MCB for UPS INPUT	2	Each				
1.1.6	32A DP MCB for UPS OUTPUT	2	Each				
1.1.7	TPN Busbar chamber having 4 nos. 25x6mm CU Bars fixed on insulators.	1	Each				
1.1.8	2 x 10A SPMCB with enclouser for continous supply of server & CCTV LINE	1	Each				
2.0	DISTRIBUTION BOARD						
2.1	Supply & erection of 415V, TPN wall mounting DB housed in Horizontal Double door DB box consisting of the following:-						
2.2.1	MDB: i) Incomer- 1 No - 63A 4P MCB (10KA). ii) Outgoing- 7 Nos. - 32 SP MCB (10KA). (UPS supply and LDB supply)	1	Set				
2.2.2	PDB / AC DB: i) Incomer -1 No- 100A 4P MCB Isolator. ii) Outgoings- 10 nos. -16/20 SP MCB (10KA).	1	Set				
3.0	Supply & erection of 230V SPN Wall mounting DB housed in SPN double door DB box consisting of the following:-						
3.1.1	LDB: i) Incomer- 1 No- 32A 2P MCB(10KA) ii) Outgoing-10 nos. -6A/10A SP MCB(10KA)	2	Set				
3.1.2	CDB:for BRANCH & ATM i) 1 no - 25A DP MCB(10KA) ii) 2 nos. - 10A SP MCB(10KA) iii) 6 nos. - 6A SP MCB(10KA)	2	Set				
3.1.3	Providing & fixing Glowsign Board point including supply of L & T Timer through Separate 20 Amps DB MCB with Metal Enclosure & 1 no. 25A SPContactor complete.(24 hrs in original Housing)	1	Set				
3.1.4	Providing & supply of AC Timer through Separate 20 Amps DB MCB with Metal Enclosure & 2 nos. 25A SPContactor complete.(24 hrs in original Housing) in the ATM room	1	Set				
4.0	DISTRIBUTION CABLE / WIRE						
4.1	Supply & lay 1.1 KV grade PVCA CU cable on wall having MS /HDP pipe protection near floor level and clamping as required for the following:-						
4.1.1	35 Sq mm 4 core AI with 2 nos 10 SWG Cu wire	40	Mtr				
4.1.2	20 Sq mm 4 core AI with 2 nos 10 SWG Cu wire	35	Mtr				
4.1.3	10 sq mm 4 core AI with 2 nos 12 SWG Cu wire	30	Mtr				
4.1.4	6 sq mm 4 core AI with 2 nos 12 SWG Cu wire	30	Mtr				

4.1.5	2.5 sq mm 2 core CU for UPS Plate Earthing	30	Mtr		
4.1.6	4 nos. 16 sq. mm. CU flexible wire through GI flexible pipe complete with end termination with CU sockets. (Meter loop connection with Main SFU & Busbar)	10	Mtr		
4.2	Making end termination of 1.1 KV grade PVCA CU cable with supply of cable end box , brass Gland, CU crimping socket & jointing materials as required for the following:-				
4.2.1	50 Sq mm 4 core CU	2	Each		
4.2.2	16 Sq mm 4 core CU	2	Each		
4.2.3	10 sq mm 4 core CU.	6	Each		
4.2.4	6 sq mm 4 core CU.	5	Each		
4.2.5	4 sq mm 2 core CU	10	Each		
5.0	16A RAW POWER OUTLET POINT WIRING Wiring for Power outlets from DB with 1.1 KV grade 2x 2.5+1x1.5 PVC insulated copper conductor wire (FRLS) through suitable size PVC conduit complete with 1 no 6/16A socket with 16A control switch in suitable size modular box with front plates (Cabtree Legrand), junction box, circular box elbows etc and all other accessories surfaced on wall above false ceiling and concealed by chase cutting on wall & making connection complete. (Maximum 2 nos. sockets cluster in one circuit connecting by looping method). 1 in Manager Room, 1 in pantry, 1 in cash cabin, 2 at work station, 1 locker and 1 in hall	6	Each		
6.1	A.C. POWER POINT WIRING A.C. power point wiring from PDB with 1.1KV grade 2 nos. single core 4.0 sq. mm + 1 no. 2.5 sq mm (Green colour for Earthing) PVC insulated copper conductor wire (FRLS)through suitable size PVC pipe on wall / ceiling surface with all wiring accessories. The work includes supply & fixing by chase cutting on wall, North West /Cabtree make Starter 18-25A (MS housed) unit with 25A socket & matching Plug top complete with all interconnections for 1.0/1.5/2 Ton ACs.	9	Each		
7.0	Wiring /cabling with 660/1100 V grade PVC insulated multi stranded copper wire/cable(FRLS) through ISI marked minimum 2-20 mm (max) thick PVC conduit with junction box, circular box, elbows, bends, couplers and other accessories concealed (below the false ceiling) or by chase cutting on wall/floor or on surface by bar saddles.				
7.1.1	2X4 + 1X 2.5 sq mm. (FOR Glow sign supply,LDB Supply)	150	Mtr		
7.1.2	1X6 SQMM CU wire for earthing	50	Mtr		
7.1.3	2X2.5 + 1x1.5 sq mm. (for UPS & Raw power Circuit & Continuous supply for server & CCTV line)	170	Mtr		
7.1.4	4X6 + 1X 2.5 sq mm. (FOR UPS POWER INPUT WIRING)	70	Mtr		
7.1.5	2X6 + 1X 2.5 sq mm. (FOR UPS POWER OUTPUT WIRING / (Lighting on & Off Invertor line wiring)	135	Mtr		
8.0	POINT WIRING:				
8.1	Supply & wiring with 3x1.5 sq. mm 1.1 KV grade PVC S/C multistrand CU wire (FRLS) in suitable size PVC conduit & accessories having control board with modular switch mounted on suitable front plate and housed in recessed MS box. The point wiring also include circuit				
	wiring with 1.1 KV grade 2 nos. single core 2.5 sq. mm +1 no. single core (green colour for Earth) PVC insulated flexible copper conductor wire through suitable size PVC conduit from DB to Switch board, interconnection and mending good all damages to original finish. (Max.8-10 points or 700- 800Watts per Circuit is allowed).				
8.1.1	One Light controlled by 6A switch	30	Each		
8.1.2	Two Light controlled by 6A switch	15	Each		
8.1.3	Exhaust Fan point with 6A switch	4	Each		
8.1.4	Bracket fan point /Ceiling Fan point with 6A switch	16	Each		

8.1.5	Modular type 6A switch, 1 no. 6A 5 pin socket point mounted on suitable front plate on separate switch board other than light / fan switch board. (Power to be tapped from nearest S.B/ LDB).	11	Each		
8.1.6	Call bell point with bell push and bell (for manager's Chamber).	1	Each		
9.0	COMPUTER POWER OUTLET CLUSTER POINT WIRING				
9.1	Computer socket outlet cluster point wiring with 1.1KV grade 2x 2.5 + 1x1.5 sq. mm. PVC insulated flexible copper conductor wire(FRLS) through suitable size PVC conduit with all accessories up to connection of 2/3 nos. sockets cluster in one circuit connecting by looping method. The work includes supply and fixing of sockets outlet cluster components as detailed below:- 1 nos.- 16A modular type switch. 3 nos. - 6/16A 5 pin modular type socket 1 each no. - Front plate & MS box. (for Each Table & counters)	11	Each		
10.0	FAN & EXHAUST FAN				
10.1	Supply, erection and connection of 400 mm 230V oscillating type full Metal body wall mounted bracket Fan.	15	Each		
10.2	Supply, erection and connection of 225 mm 1400 rpm, 230V Heavy duty exhaust Fan with wire guard net including wall cutting and finishing. Providing and Fixing ceiling fans 1200 mm. sweep including 600 v electronic regulator & MS hook with hanging arrangement.	4	Each		
		2	unit		
11.0	Call Bell Supply and fixing of call bell with modular type push complete with plate & box to be fixed (1 each in Floor)	1	Each		
12.0	LIGHT FITTINGS Supply, erection and connection of fluorescent / compact fluorescent / mini halogen fitting with lamp , ballast / Transformer and other accessories for the following as per approved Brand/Make of Materials.				
12.1.1	36 W 2 X 2 LED LIGHTS	31	Each		
12.1.2	15 W LED DOWN LIGHTERS	8	Each		
12.1.3	20 W LED TUBE LIGHT	22	Each		
12.1.14	LED LIGHT STRIPS (@5MT= 1 ROLL)	2	ROLLS		
12.1.4	5A 12 V DRIVER 12NC	2	SET		
13.0	TELEPHONE CABLE Supply, lay and connect PVC insulated CU conductor and armoured 10 pair Telephone cable for the following:-	50	Mtr		
14.0	TELEPHONE POINT				
14.1	Telephone point wiring with 2 pair PVC insulated CU conductor (0.5mm) telephone wire drawn through PVC conduit.	3	Each		
14.2	Supply and erection of modular type telephone outlet RJ11 mounted on suitable front plate housed in recessed MS box.	3	Each		
15.0	EARTHING				
15.1.1	Supply and election Earth station with 600 x600x3mm GI Plate with earth strip / wire connecting arrangement including excavation and back filling with 25 mm dia GI pipe for watering.(for UPS & LIGHT FAN Earthing)	2	Each		
15.1.2	Supply and erection of masonry pit for each Earth station having CI/RCC inspection cover.	2	Each		
16.0	Supply and erection of earth bus on wall (min. length 0.3 mtr.) on insulator with drilled holes on the bus with GI bolt , nut , washer etc for the following:-				
16.1.1	With (25x6) mm GI flat	2	Each		
16.1.2	With (25x3) mm CU flat	2	Each		
17.0	Supply and lay GI flat for earthing underground /on wall including connection for the following:-				
17.1	(25x3)mm Cu flat	70	Mtr		
GROSS TOTAL (Rs.) GST EXTRA AS APPLICABLE					