

**CORRIGENDUM**

**REPLACEMENT, SUPPLY, INSTALLATION, TESTING, COMMISSIONING & 05 YEARS COMPREHENSIVE MAINTENANCE OF 02 NOS. NEW PASSENGER LIFTS (13 PASSENGER CAPACITY) AT CIRCLE OFFICE, BELLS HOUSE, 21, CAMAC STREET, KOLKATA- 700016**

**TENDER REFERENCE NO: 28/22-23/BDS dated 20.07.2022**

\*\*\*\*\*

	<b>Query</b>	<b>Reply</b>
1	Whether OEM (Original Equipment Manufacturer) can participate in the tender?	Yes, OEM (Original Equipment Manufacturers) can participate in the tender.
2	As per page no. 63 and 65 of tender document, stops and openings- 10 stops/ 10 openings (G + 9) floor.	(G + 10) floors. 11 stops/ 11 landings
3	Time of completion	No change. Time of completion will be as per tender document.
4	Quantity of fire extinguishers required?	One fire extinguisher for each floor.
5	Payment terms	No change. Payment terms will be as per tender document.

